



Environmental and Laboratory Services
 90 ½ West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: July 11, 2017
Client: Nutley Board of Education
Address: 315 Franklin Ave
 Nutley, NJ 07110

Project: Nutley High School

Sample description: Drinking Water / 1st Draw / DWS5731-1
Sample location: Field Blank
Sampled by: S. Flyte / S. Berta
Sample date: 06/17/17
Time: 06:35
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	16:21	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-2
Sample location: NHS-KO-Kitchen-01
Sampled by: S. Flyte / S. Berta
Sample date: 06/17/17
Time: 06:45
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	16:46	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-3
Sample location: NHS-KO-Kitchen-02
Sampled by: S. Flyte / S. Berta
Sample date: 06/17/17
Time: 06:45
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	16:53	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-4
Sample location: NHS-FC-HW-by A123-01
Sampled by: S. Flyte / S. Berta
Sample date: 06/17/17
Time: 06:53
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	16:59	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-5
 Sample location: NHS-FC-HW-by A123-02
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 06:53
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.31 µg/L	15 µg/L	06/26/17	17:06	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-6
 Sample location: NHS-FC-WH by A123-03
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 06:54
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	17:11	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-7
 Sample location: NHS-TL-Teacher Lounge
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 06:57
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	17:18	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-8
 Sample location: NHS-FC-HW-by Rm 124-01
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:03
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	17:04	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-9
 Sample location: NHS-FC-HW-by Rm 124-02
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:04
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	17:30	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-10
 Sample location: NHS-FC-HW-by Guidance
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:05
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	17:43	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-11
 Sample location: NHS-MO-Nurse
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:07
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	17:50	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-12
 Sample location: NHS-FC-HW-by Rm 102-01
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:13
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	17:57	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-13
 Sample location: NHS-FC-HW-by Rm 102-02
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:14
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	18:02	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-14
 Sample location: NHS-FB-Gym Rear SE
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:17
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	18:09	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-15
 Sample location: NHS-FB-Girls Locker Rm 01
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:20
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.48 µg/L	15 µg/L	06/26/17	18:16	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-16
 Sample location: NHS-FC-Girls Locker Rm 02
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:20
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	18:23	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-17
 Sample location: NHS-FB-by Girls LR
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:22
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	424 µg/L	15 µg/L	06/28/17	17:21	100	200 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-18
 Sample location: NHS-FB-Rear of Gym SO West
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:24
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.16 µg/L	15 µg/L	06/26/17	18:29	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-19
 Sample location: NHS-FB-Boys Locker Rm 01
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:37
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.53 µg/L	15 µg/L	06/26/17	18:35	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-20
 Sample location: NHS-FB-Varsity JV Locker Rm
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:45
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	18:41	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-21
 Sample location: NHS-FC-Weight Rm
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:47
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	19:06	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-22
 Sample location: NHS-FC-HW by A238-01
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:56
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	19:33	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-23
 Sample location: NHS-FC-HW by A238-02
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:56
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	19:39	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-24
 Sample location: NHS-FC-HW by A238-03
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 07:57
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	19:46	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-25
 Sample location: NHS-HE-Rm 225-01
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:00
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	19:52	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-26
 Sample location: NHS-HE-Rm 225-02
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:00
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	19:59	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-27
 Sample location: NHS-HE-Rm 225-03
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:01
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	20:05	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-28
 Sample location: NHS-HE-Rm 225-04
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:01
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	20:11	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-29
 Sample location: NHS-HE-Rm 221-01
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:03
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	20:18	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-30
 Sample location: NHS-HE-Rm 221-02
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:03
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	20:31	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-31
 Sample location: NHS-HE-Rm 221-03
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:04
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	20:37	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-32
 Sample location: NHS-HE-Rm 221-04
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:04
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	20:44	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-33
 Sample location: NHS-HE-Rm 221-05
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:05
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	20:50	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-34
 Sample location: NHS-HE-Rm 221-06
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:05
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	20:57	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-35
 Sample location: NHS-FC-HW by Rm 217
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:06
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	21:04	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-36
 Sample location: NHS-FB-HW by Rm 214-01
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:09
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	21:10	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-37
 Sample location: NHS-FB-HW by Rm 214-02
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:09
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	21:16	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-38
 Sample location: NHS-SO-Rm 214
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:10
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.62 µg/L	15 µg/L	06/26/17	21:23	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-39
 Sample location: NHS-FC-HW by Rm A325-01
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:14
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	21:30	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-40
 Sample location: NHS-FC-HW by Rm A325-02
 Sampled by: S. Flyte / S. Berta
 Sample date: 06/17/17
 Time: 08:14
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	21:54	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-41
Sample location: NHS-FC-HW by Rm A325-03
Sampled by: S. Flyte / S. Berta
Sample date: 06/17/17
Time: 08:15
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	22:18	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-42
Sample location: NAS-S B01-POE
Sampled by: S. Flyte / S. Berta
Sample date: 06/17/17
Time: 06:40
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	72.9 µg/L	15 µg/L	06/26/17	22:30	4	8.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-43
Sample location: NAS-Cafe-WF-03
Sampled by: S. Flyte / S. Berta
Sample date: 06/17/17
Time: 06:48
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	22:36	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-44
Sample location: NAS-Trainer FC-01
Sampled by: S. Flyte / S. Berta
Sample date: 06/17/17
Time: 07:41
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	22:42	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-45
Sample location: NAS-Trainer IM-02
Sampled by: S. Flyte / S. Berta
Sample date: 06/17/17
Time: 07:42
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	22:48	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5731-46
Sample location: NAS-FC-Weight Rm-02
Sampled by: S. Flyte / S. Berta
Sample date: 06/17/17
Time: 07:47
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	06/26/17	22:54	1	2.00 µg/L

$\mu\text{g/L}$ = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen (For SV)
Susan VanVeen, Lab Manager
NJ Laboratory Certification ID # 14013

July 21, 2017
Date

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

_____ Asc./HCl Vials pH: _____
 # _____ HCl Vials pH: _____
 # _____ Na₂S₂O₃ Cl₂: _____
 # 46 HNO₃ (350ml) pH: 12
 # _____ H₂SO₄ pH: _____
 # _____ NaOH pH: _____
 # _____ unpreserved _____
 # _____ other _____
 # _____ other _____

Customer Name: <u>Nutley HS</u>	report to: _____	Agra Environmental Services
Address: <u>300 Franklin Ave</u> <u>Nutley NJ 07110</u>	<u>Philip Nicolette</u>	<u>90 1/2 West Blackwell Street</u> <u>Dover, NJ 07801</u>
County/Municipality: <u>Phil Nicolette</u>		Phone: <u>(973) 989-0010</u>
Phone: <u>973-661-8813 office</u>		Fax: <u>(973) 989-0156</u>
Work: _____		

Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake

Project:		Collection		PWSID# NJ					for laboratory use only	Field Analysis
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	
<u>D055731</u>										
		<u>6/17/17</u>	<u>1304</u>	<u>X</u>			<u>1</u>	<u>NHO3</u>	<u>1ST DRAW PB</u>	
Field Blank	<u>-1</u>	<u>6/17/17</u>	<u>0635</u>	<u>X</u>			<u>1</u>	<u>NHO3</u>	<u>1ST DRAW PB 2.00 ug/L 6/26/17 1621B</u>	
NHS-KO-KITCHEN-01	<u>-2</u>	<u>6/17/17</u>	<u>0645</u>	<u>X</u>			<u>1</u>	<u>NHO3</u>	<u>1ST DRAW PB 2.00 1646</u>	
NHS-KO-KITCHEN -02	<u>-3</u>	<u>6/17/17</u>	<u>0645</u>	<u>X</u>			<u>1</u>	<u>NHO3</u>	<u>1ST DRAW PB 2.00 1653</u>	
NHS-FC-HW-by A123-01	<u>-4</u>	<u>6/17/17</u>	<u>0653</u>	<u>X</u>			<u>1</u>	<u>NHO3</u>	<u>1ST DRAW PB 2.00 1659</u>	
NHS-FC-HW-by A123-02	<u>-5</u>	<u>6/17/17</u>	<u>0653</u>	<u>X</u>			<u>1</u>	<u>NHO3</u>	<u>1ST DRAW PB 2.31 1706</u>	
NHS-FC-WH BY A123-03	<u>-6</u>	<u>6/17/17</u>	<u>0654</u>	<u>X</u>			<u>1</u>	<u>NHO3</u>	<u>1ST DRAW PB 2.00 1711</u>	
NHS-TL-Teacher Lounge	<u>-7</u>	<u>6/17/17</u>	<u>0657</u>	<u>X</u>			<u>1</u>	<u>NHO3</u>	<u>1ST DRAW PB 2.00 1718</u>	
NHS-FC-HW-by rm A124-01	<u>-8</u>	<u>6/17/17</u>	<u>0703</u>	<u>X</u>			<u>1</u>	<u>NHO3</u>	<u>1ST DRAW PB 2.00 1704</u>	
NHS-FC-HW-by RM A124-02	<u>-9</u>	<u>6/17/17</u>	<u>0704</u>	<u>X</u>			<u>1</u>	<u>NHO3</u>	<u>1ST DRAW PB 2.00 1730</u>	

Sampled By (name/company): <u>SFLSB</u>	State Forms Needed (circle one): Yes or No		indicate laboratory location where analysis requested was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013		
	NJDEP Laboratory Certification (Marlboro, NJ) #13033		

Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:
-------------------------------------	----------	------------	-----------------	---

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By: <u>Sherry Duke</u>	Date: <u>6/17/17</u>	Time: <u>1304</u>	Received By: <u>[Signature]</u>	Date: <u>6/17/17</u>	Time: <u>1305</u>	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
						Date Faxed _____
						Invoice Number _____
						Is sample known to be hazardous? (circle one) Yes or No

#NAME?

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Nutley HS		report to:		Agra Environmental Services			
Address: 300 Franklin Ave		Philip Nicolette		90½ West Blackwell Street			
Nutley NJ 07110				Dover, NJ 07801			
County/Municipality: Phil Nicolette				Phone: (973) 989-0010			
Phone: 973-661-8813 office				Fax: (973) 989-0156			
Work:							
Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake							Page <u>1</u> of <u>1</u>
Project:		Collection		PWSID# NJ			for laboratory use only
Lab ID:							Field Analysis
Field ID	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative
ANALYSIS REQUESTED							
D55731 NHS-FC-HW-by Guidance -10	6/17/17	0705	X			1	NH03
NHS-MO-Nurse -11	6/17/17	0707	X			1	NH03
NHS-SO-Conference RM	6/17/17		X			1	NH03
NHS-FC-HW-by Rm 102 -01 -12	6/17/17	0712	X			1	NH03
NHS-FC-HW-by Rm 102 -08	6/17/17	0714	X			1	NH03
NHS-FB-Gym Girls Side Rear SE	6/17/17	0717	X			1	NH03
NHS-FB-GIRLS-LOCKER RM 01	6/17/17	0720	X			1	NH03
NHS-FC-GIRLS LOCKER RM 02	6/17/17	0720	X			1	NH03
NHS-FC-TEAM RM Forth Girls LR	6/17/17	0722	X			1	NH03
NHS-FB-Rear of Gym So East West	6/17/17	0724	X			1	NH03
Sampled By (name/company):		State Forms Needed (circle one): Yes or No			indicate laboratory location where analysis requested was performed		
SF/SB		NJDEP Laboratory Certification (Dover, NJ) #14013					
		NJDEP Laboratory Certification (Marlboro, NJ) #13033					
Reporting Requirements (Check Box):		Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:		
Sample Custody Exchanges (Please use full legal signature)						Scanned _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No	

#NAME?

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Nutley HS	report to:	Agra Environmental Services
Address: 300 Franklin Ave Nutley NJ 07110	Philip Nicolette	90½ West Blackwell Street Dover, NJ 07801
County/Municipality: Phil Nicolette		Phone: (973) 989-0010
Phone: 973-661-8813 office		Fax: (973) 989-0156
Work:		



Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project: _____ Collection _____ PWSID# NJ _____ for laboratory use only _____ Field Analysis _____

Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	Field Analysis	
<i>DW557M</i>											
NHS-FB-Rear of Gym So West		6/17/17		X			1	NHO3	1ST DRAW PB		
NHS-FB-Boys Locker RM 01 -19		6/17/17	0737	X			1	NHO3	1ST DRAW PB 2.53 ug/L 6/16/17 1835	BM	
NHS-FB-Boys Locker RM 02		6/17/17		X			1	NHO3	1ST DRAW PB	No sample - pressure too low	
NHS-FB-Rear of Gym So. West		6/17/17		X			1	NHO3	1ST DRAW PB		
NHS-FB-Varsity JV Locker RM -20		6/17/17	0745	X			1	NHO3	1ST DRAW PB 2.00 ug/L 6/16/17 1841	BM	
NHS-FC-Weight Rm -81 -21		6/17/17	0747	X			1	NHO3	1ST DRAW PB 2.00	1906	
NHS-FC-HW by A238-01 -22		6/17/17	0756	X			1	NHO3	1ST DRAW PB 2.00	1933	
NHS-FC-HW by A238-02 -23		6/17/17	0756	X			1	NHO3	1ST DRAW PB 2.00	1934	
NHS-FC-HW by A238-03 -24		6/17/17	0757	X			1	NHO3	1ST DRAW PB 2.00	1946	
NHS-HE-RM 225-01 -25		6/17/17	0800	X			1	NHO3	1ST DRAW PB 2.00	1952	

Sampled By (name/company): *SP/SB* State Forms Needed (circle one): Yes or No _____ indicate laboratory location where analysis requested was performed _____

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify) _____ Cooler Temperature Upon Receipt at lab: _____

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Scanned _____ Date Faxed _____ Invoice Number _____ Is sample known to be hazardous? (circle one) Yes or No
<i>Sherry Ayres</i>	6/17/17	1304	<i>[Signature]</i>	6/17/17	1305	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Nutley HS	report to:	Agra Environmental Services
Address: 300 Franklin Ave	Philip Nicolette	90½ West Blackwell Street
Nutley NJ 07110		Dover, NJ 07801
County/Municipality: Phil Nicolette		Phone: (973) 989-0010
Phone: 973-661-8813 office		Fax: (973) 989-0156
Work:		



Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project:		Collection		PWSID# NJ					for laboratory use only	Field Analysis	
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED		
NHS-HE-RM 225-02	-26	6/17/17	0800	X			1	NH03	1ST DRAW PB 2.00 ug/L 6/26/17 1459	BM	
NHS-HE-Rm 225-03	-27	6/17/17	0801	X			1	NH03	1ST DRAW PB 2.00	2005	
NHS-HE-Rm225-04	-28	6/17/17	0801	X			1	NH03	1ST DRAW PB 2.00	2011	
NHS-HE-Rm221-01	-29	6/17/17	0803	X			1	NH03	1ST DRAW PB 2.00	2018	
NHS-HE-Rm 221-02	-30	6/17/17	0803	X			1	NH03	1ST DRAW PB 2.00	2031	
NHS-HE-RM221-03	-31	6/17/17	0804	X			1	NH03	1ST DRAW PB 2.00	2037	
NHS-HE-Rm 221-04	-32	6/17/17	0804	X			1	NH03	1ST DRAW PB 2.00	2044	
NHS-HE-Rm 221-05	-33	6/17/17	0805	X			1	NH03	1ST DRAW PB 2.00	2050	
NHS-HE-Rm 221-06	-34	6/17/17	0805	X			1	NH03	1ST DRAW PB 2.00	2057	
NHS-FC-HW by RM 217	-35	6/17/17	0806	X			1	NH03	1ST DRAW PB 2.00	2104	

Sampled By (name/company): SE/SB	State Forms Needed (circle one): Yes or No				indicate laboratory location where analysis requested was performed	
	NJDEP Laboratory Certification (Dover, NJ) #14013					
	NJDEP Laboratory Certification (Marlboro, NJ) #13033					
Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:		

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
<i>Sherry Pappas</i>	6/17/17	1304	<i>[Signature]</i>	6/17/17	1305	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

Customer Name: Nutley HS	report to:	Agra Environmental Services
Address: 300 Franklin Ave	Philip Nicolette	90½ West Blackwell Street
Nutley NJ 07110		Dover, NJ 07801
County/Municipality: Phil Nicolette		Phone: (973) 989-0010
Phone: 973-661-8813 office		Fax: (973) 989-0156
Work:		



Matrix Abbreviations: D - Drinking Water G- Groundwater W- Wastewater S- Soil SL- Sludge P-Pool L-Lake Page 1 of 1

Project:	Collection	PWSID# NJ							for laboratory use only	Field Analysis
Field ID	Lab ID:	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	
<i>DW55731</i> NHS-FC-HW by RM 214-01 -36		6/17/17	0809	X			1	NH03	1ST DRAW PB 2.00 <i>upll 6/26/17 210 BM</i>	
NHS-FC-HW by RM 214-02 -37		6/17/17	0809	X			1	NH03	1ST DRAW PB 2.00	216
NHS-SO-Rm 214 -38		6/17/17	0810	X			1	NH03	1ST DRAW PB 7.62	213
NHS-FC-HW by RM A325-01 -39		6/17/17	0814	X			1	NH03	1ST DRAW PB 2.00	2130
NHS-FC-HW by RM A325-02 -40		6/17/17	0814	X			1	NH03	1ST DRAW PB 2.00	2154
NHS-FC-HW by RM A325-03 -41		6/17/17	0815	X			1	NH03	1ST DRAW PB 2.00	2218
<i>NHS-SB01 -PDE -42</i>		6/17/17	0640	X			1	NH03	1ST DRAW PB 72.4	2230 1:4
<i>NHS-ROFE-WF-03 -43</i>		6/17/17	0648	X			1	NH03	1ST DRAW PB 2.00	2236
<i>NHS-Trainer EC -01 -44</i>		6/17/17	0941	X			1	NH03	1ST DRAW PB 2.00	2242
<i>NHS-Trainer IM-02 -45</i>		6/17/17	0948	X			1	NH03	1ST DRAW PB 2.00	2248

Sampled By (name/company): <i>SE/SB</i>	State Forms Needed (circle one): Yes or No				indicate laboratory location where analysis requested was performed	
	NJDEP Laboratory Certification (Dover, NJ) #14013					
	NJDEP Laboratory Certification (Marlboro, NJ) #13033					
Reporting Requirements (Check Box):	Standard	NJ Reduced	Other (Specify)	Cooler Temperature Upon Receipt at lab:		

Sample Custody Exchanges (Please use full legal signature)						Scanned _____
Relinquished By: <i>Thony Pato</i>	Date: 6/17/17	Time: 1304	Received By: <i>[Signature]</i>	Date: 6/17/17	Time: 1305	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one) Yes or No

